
ADDENDUM No. 1

TO: ALL BIDDERS OF RECORD

PROJECT: Wall Creek Bunkhouse Reroof Project
FWP# 15-07

DATE: August 27, 2014

FROM: Daniel Stinson, Project Manager
Montana Fish Wildlife & Parks

Acknowledge receipt of this addendum by inserting it's number and date in the proposal form. Failure to do so may subject bidder to disqualification.

This Addendum forms a part of the Contract Documents. Clarification and/or modifications are as follows:

1) APPROVED SUBSTITUTIONS

The Project Description specifies, "new mechanically seamed steel roofing panels with a 1" to 2½" standing rib, utilizing a hidden floating clip system and optional sealant, suitable for the existing roof slope. Panels shall be of minimum 24 gauge (.0250") steel and panel width shall be between 16" and 20". The Description further states "The steel roof system shall be warranted against winds of up to 110 MPH and to remain sound, weathertight and fully functional for a period of at least 30 years."

It has been requested that a substitution of a mechanical locking roof system be allowed such as Bridger Steel "Tru-Snap". Such a substitution shall be acceptable **IF** such a substitution is made clear in the submittals and if all other warranted conditions are met or bettered.

2) CLARIFICATIONS

FINISH - The Project Description states, "The finished roof color shall be similar to current adjacent shop roof and the finish shall be warranted for 30 years."

The finish must be identified in the submittals. All panels shall be completely covered with the finish, so that there are no bare faces on any of the finished panels. Finish information shall be included in the submittals.

END OF ADDENDUM #1